



The company named below has been authorized by Canadian Standards Association to represent the products listed in this record as "CSA Certified" or "CSA Accepted", as applicable, and to affix the CSA Mark to these products according to the terms and conditions of the CSA Service Agreement and applicable CSA program requirements (including additional Markings).

NUMBR 092374X0000 July 12, 1996 (Replaces: December 13, 1995)

CLASS 3211 07 (Re-examination Service)

IDEC IZUMI CORP.
7-31 Nishimiyahara 1-Chome
Yodogawa-Ku
Osaka 532, Japan
FACTORY
Takino Plant - (F1 MASTER)
355-18 Aza-Kuroishi, Oaza-Kohtaka
Takino-Cho, Kato-Gun
Hyogo-Ken 679-02, Japan
SEE ALSO SATELLITE FACTORY FILE LR 107101.

92374

INDUSTRIAL CONTROL EQUIPMENT - Miscellaneous Apparatus

- Transformers for use with submittor's LED type pilot lamps AP2M and AP6M respectively, Models AP2 and AP6, open type, rated primary 230/240V ac max, 1.6VA max, load 6V dc, 36mA.
- LED Type miniature pilot lights AP1M, AP2M, AP6M and AP8M, operating voltages 6, 12, 24 V dc.
- Transformers for pilot lights, Type HW-R and HW-F, input rated 100 to 480 V, 50/60 Hz, Type HW-M, input rated 100 to 240 V, 50/60 Hz, for assembling with operator units, Type HW with suffixes and lamp.
- Pilot light without transformer, Type HW-P, input rated 6 to 120 V, applicable lamp rating, incandescent lamp 6.3, 18, 24 and 30 V, 1 W and LED lamp 6, 12, 24 and 120 V.

Notes:

1. Open type devices are Certified as components for use only in other Certified types where the suitability of the combination is to be determined by the Canadian Standards Association.
2. Suffix designations indicate mechanical variations.
3. Barriers may be necessary in certain applications to insure proper spacing.

* * * * *

